

CITY OF PORT ST. JOE, FLORIDA
NOTICE TO RECEIVE SEALED BIDS
RFP 2020-16
Sodium Hypochlorite

Sealed bids for City of Port St. Joe for Sodium Hypochlorite will be received at City Hall, 305 Cecil G. Costin Sr. Blvd., Port St. Joe, Florida 32456 up until 4:00 PM EST, Friday September 18, 2020. Bids will be publicly opened and acknowledged, Friday, September 18, 2020, at 4:05 PM EST, in the City Commission Conference Room.

Bids shall be submitted in a sealed envelope, plainly marked with bidder's name, address, date and time of opening, and "RFP Number 2020-16 for Sodium Hypochlorite."

DESCRIPTION OF WORK: A complete bid package is available at the City's website: www.cityofportstjoe.com

For questions concerning this project, please contact Larry McClamma at 850-229-1421.

The City of Port St. Joe reserves the right to accept or reject any and all Statements of Bids in whole or in part, to waive informalities in the process, to obtain new Statements of Bids, or to postpone the opening pursuant to the City's purchasing policies. Each Statement of Bid shall be valid to the City of Port St. Joe for a period of sixty (60) days after the opening.

The City of Port St. Joe is an Equal Opportunity, Affirmative Action Employer, and a Drug Free Work place.

Sodium Hypochlorite 12.5 wt% Bacticide

<u>Characteristic</u>	<u>Unit</u>	<u>Value</u>	<u>Min</u>	<u>Max</u>
Sodium Hypochlorite, NaOCl , wt%	wt%	13.2	12.5	15.6
Available Chlorine, gpl	gpl	150.6	145	185
Total Alkalinity as NaOH, gpl	gpl	10.5	1.2	29
Total Alkalinity as NaOH, wt%	wt%	0.9	0.1	2.3
Actual Sodium Hydroxide, NaOH , wt%	wt%	0.4	0.1	1.5
Sodium Carbonate, Na_2CO_3 , wt%	wt%	0.6		1.1
Density @ 20 C	g/ml	1.2		

SWTP Chemical Deliveries

Delivery Location: 309 Water Plant Road, Port St. Joe, Florida 32456

Delivery Times: 7:00 am eastern to 3:00 pm eastern

Sodium Hypochlorite: Estimated Quantity Per Delivery: 4500 gallons (Chemical Storage Tank 2x4000 gallons)

PPE is a requirement for all delivery drivers. No exceptions.