

## Port St Joe Wastewater Treatment Plant Bar Screen Replacement

Location: 250 Kenny Mill Road, Port St Jo, FL 32456

Contact : Kevin Pettis or Joe Harris at (850)229-6395, -or- [kpettis@psj.fl.gov](mailto:kpettis@psj.fl.gov), [jharris@psj.fl.gov](mailto:jharris@psj.fl.gov)

Current bar screen is: Schreiber 48" Front loader Bar Screen.

Channel Depth 4'8".

480/120V AC.

Replacement Bar Screen Must Meet the Following Criteria:

- Parkson Aqua Guard system
- Ability to handle 10 MGD flow rate
- Turnkey Project. All electrical, mechanical, controls, and supplies are to be included with this project.
- Screen should be able to remove heavy debris such as towels, jeans, rags, etc.
- Screening should be able to screen out anything larger than 3/8" wide.
- All bolting hardware is to be s/s hardware.
- O&M manual on site for review
- Replacement parts available in the U.S.
- Must connect to our existing SCADA system for fault monitoring.
- Will accept separate bids per company for different styles or brands.